



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

August 17, 2022

Vivian Cooper
Emagination Station Child Care Center LLC
12451 East 8 Mile Road
Warren, MI 48089

| | |
|----------------|--|
| RE: License #: | DC500397102 Emagination Station Child Care Ctr 12451 East 8 Mile Road Warren, MI 48089 |
|----------------|--|

Dear Ms. Cooper:


This letter is a follow-up to the Department’s findings regarding the interim inspection conducted at your center on 08/16/2022. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for Child Care Centers.

The violations that were found are:

| | |
|--|---|
| R 400.8134 | Hand washing. |
| | (4) Guidelines for hand washing must be posted in food preparation areas, in toilet rooms, and by all hand washing sinks. |
| I observed that there were no guidelines posted for handwashing in the restroom. | |
| R 400.8315 | Food and equipment storage. |
| | (1) Each refrigerator must have an accurate working thermometer indicating a temperature of 41 degrees Fahrenheit or below. |

| | |
|--|--|
| I observed during the onsite inspection that the refrigerator did not have the required thermometer. | |
| R 400.8545 | Fire extinguishers. |
| | (1) Multipurpose fire extinguishers, having ratings of not less than 2A-10BC, shall be installed in or adjacent to the kitchen or cooking area and in or adjacent to the door of the heating plant room. |
| I observed during the onsite inspection that there was a 1A-10BC fire extinguisher installed in the kitchen. A 2A-10BC extinguisher is required. | |

Sincerely,



Stephanie A. Williams, Licensing Consultant
 Bureau of Community and Health Systems
 611 W. Ottawa Street
 P.O. Box 30664
 Lansing, MI 48909
 (586) 744-8940