



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

February 22, 2022

Dawn VanderWall
1841 76th Avenue
Zeeland, MI 49464

RE: License # DF700084196
 Dawn Vanderwall
 1841 76th Avenue
 Zeeland, MI 49464

Dear Ms. VanderWall:

This letter is a follow-up to the photographic documentation you submitted to the bureau to verify compliance with the following rule during your renewal inspection on February 2, 2022.

The violations that were found are:

R 400.1944(3) Smoke detectors; fire extinguishers.

(3) A home shall have at least 1 functioning multipurpose fire extinguisher, with a rating of 2A-10BC or larger, properly mounted not higher than 5 feet from the floor to the top of the fire extinguisher, on each floor level approved for child use.

On February 19, 2022, Ms. VanderWall submitted a photograph of the fire extinguisher on the main level of the room mounted no higher than 5 feet from the floor.

You can find a copy of this confirming letter and any associated corrective action plans on our [website](#) under [Statewide Search for Licensed Child Care Centers and Homes](#). A description of when confirming letters are completed can be found under [Overview of Licensing Reports](#).

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (517) 284-9730.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your Licensing Notebook.

Sincerely,

A handwritten signature in black ink, appearing to read 'JMB', is positioned above the printed name.

Jessica Miranda-Bevier, Licensing Consultant
Child Care Licensing Bureau
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909
(616) 498-5459