



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
ACTING DIRECTOR

August 22, 2023

Angela Cross
601 N. Spring St.
Durand, MI 48429

RE: License #: DF780409965
Gigi's Zero To Three Family Childcare
601 N. Spring Street
Durand, MI 48429

Dear Mrs. Cross:

This letter is a follow-up to the Department's findings regarding the interim inspection conducted at your home on 08/22/2023. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for Family and Group Child Care Homes.

The violations that were found are:

R 400.1933 **Water supply; sewage disposal; water temperature.**

(4) Hot water temperature must not exceed 120 degrees Fahrenheit at water faucets accessible to children.

Mrs. Cross water temperature was above 120 degrees Fahrenheit where children washed their hands.

R 400.1941

Heat-producing equipment.

(2) Combustible materials and equipment must not be stored within 4 feet of furnaces, other flame or heat-producing equipment, or fuel-fired water heaters.

The room that had the furnace was cluttered with boxes, blankets and other combustible materials.

On 8/22/2023, you gave us an acceptable written corrective action plan.

You can find a copy of this inspection letter and any associated corrective action plans on our [website](#) under [Statewide Search for Licensed Child Care Centers and Homes](#). A description of when inspection letters are completed can be found under [Overview of Licensing Reports](#).

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at 517-284-9730.

Per MCL 722.113g, this report and any related corrective action plans must be filed in your Licensing Notebook.

Sincerely,



Angela Histed, Licensing Consultant
Bureau of Community and Health Systems
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909
(248) 917-1607