



Andy Beshear
GOVERNOR

CABINET FOR HEALTH AND FAMILY SERVICES
OFFICE OF INSPECTOR GENERAL

Melissa A. Moore, Director
Division of Regulated Child Care
Southern Branch
116 Commerce Ave
London, KY 40744
Phone: (606) 330-2030 Fax: (606) 330-2056
<https://chfs.ky.gov/agencies/os/oig>

Eric Friedlander
SECRETARY

Adam Mather
INSPECTOR GENERAL

Inspection Report

Provider Name: Noah's Ark Daycare Center	Provider Information	License No: L356929
Provider Address: 524 Avondale Avenue, Middlesboro, KY, 40965	Provider Type: LICENSED TYPE I	Capacity: 60
Owner(s): Kelly, Edith S		Director(s): Cupp, Melissa

Inspection Type: Change of Location	Inspection Information	Inspection No: 10102
Visit Start Date: 05/25/2012 11:00 AM	Visit End Date: 05/25/2012 1:00 PM	
	No. of Children Present: 15	

Inspection Report

General Premises

197 - Premises Requirements

922 KAR 2:120 - Section 4 Premises Requirements.

(1) The premises shall be:

- (a) Suitable for the purpose intended;**
- (b) Kept clean and in good repair; and**
- (c) Equipped with a land-line telephone accessible to a room used by a child.**

1) Suitable

In Compliance

2) Clean

In Compliance

3) Good repair

In Compliance

199 - Fire exits clear

In Compliance

922 KAR 2:120 - Section 4

- (3) Fire and emergency exits shall be kept clear of debris.**

200 - Building Requirements

922 KAR 2:120 - Section 4

(4) The building shall be constructed to ensure the:

(a) Building is:

- 1. Dry;**
- 2. Adequately heated;**
- 3. Ventilated; and**
- 4. Well lit, including clean light fixtures:**
 - a. That are in good repair in all areas; and**
 - b. Shielded or have shattered proof bulbs installed; and**

1) Dry

In Compliance

2) Adequately heated

In Compliance

3) Adequately ventilated

In Compliance

4) Well Lit

In Compliance

5) Clean Light Fixtures

In Compliance

6) Lights good repair

In Compliance

Inspection Report

7) Shielded/shatter proof bulbs

In Compliance

205 - Floors, walls, Ceilings

922 KAR 2:120 - Section 4

(8) Floors, walls, and ceilings shall be smooth, in good repair, and constructed to be easily cleaned.

1) Floors smooth/good repair

In Compliance

2) Walls smooth/good repair

In Compliance

3) Ceilings smooth/good repair

In Compliance

4) Floors easily cleaned

In Compliance

5) Walls easily cleaned

In Compliance

6) Ceilings easily cleaned

In Compliance

212 - Building Temperature

922 KAR 2:120 - Section 4

(15) The temperature of the inside area of the premises shall be:

(a) Sixty-five (65) to seventy-five (75) degrees Fahrenheit during the winter; or

(b) Sixty-eight (68) to eighty-two (82) degrees Fahrenheit during the summer months.

2) Summer Temperature sixty-eight to eighty-two

In Compliance

278 - Minimum Toilet/Urinal requirements

In Compliance

922 KAR 2:120 - Section 10

(1) A child-care center shall have a minimum of one (1) toilet and one (1) lavatory for each twenty (20) children. Urinals may be substituted for up to one-half (1/2) of the number of toilets required for a male toilet room.

Signature of
Provider/Representative

Title

Date