

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **M & M Daycare**

City: **Huron**

Provider Number: **000097080**

Inspector: **Carrie Lewis**

Date of Inspection: **10/27/2020**

Time of Inspection: **8:06 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

<p>Corrections To Be Made:</p> <p>The water temperature in the basement was at 134.7 F.</p> <p>*The water heater temperature was lowered and the temperature for the basement sinks were measured to be between 105--110 degrees F.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/28/2020</td> <td style="text-align: center;">10/28/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/28/2020	10/28/2020
Suggested Completion Date:	Actual Completion Date:				
10/28/2020	10/28/2020				

Marianne Freng

10/27/2020

Provider Signature

Date

Carrie Lewis

10/27/2020

Inspector Signature

Date