

Family Day Care Inspection Compliance Plan

Provider's Name: **Kellie Cole**

City: **Hermosa**

Provider Number: **010603750**

Inspector: **Tina Uecker**

Date of Inspection: **11/19/2019**

Time of Inspection: **9:04 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health & Safety Features of the Home - Indoor Environmental Observations

69. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower?
67:42:03:11.05

<p>Corrections To Be Made:</p> <p>Provider's hot water exceed 120 degrees. Water must be less than 120 degrees.</p> <p>*Provider lowered the hot water temperature so that it did not exceed 120 degrees.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">12/05/2019</td> <td style="text-align: center;">12/05/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	12/05/2019	12/05/2019
Suggested Completion Date:	Actual Completion Date:				
12/05/2019	12/05/2019				

Kellie Cole

Provider Signature

11/19/2019

Date

Tina Uecker

Inspector Signature

11/19/2019

Date