

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Storytime Preschool & Child Center**

City: **North Sioux City**

Provider Number: **010604217**

Inspector: **Stacy Wildermuth**

Date of Inspection: **06/10/2020**

Time of Inspection: **9:15 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

7. In Licensed Day Care Programs Caring for 21 or More Children - Is a fire alarm system installed in the building wiring and operable? 61:15:05:08 NOTE: Manual pull stations, audible alarms inside and out. Smoke detectors are in stairwells, corridors, lounges, recreation and sleeping areas.

<p>Corrections To Be Made:</p> <p><b>Documentation for a current fire alarm inspection was not available. The fire alarm system should be inspected annually.</b></p> <p><b>***The fire alarm inspection was received by Child Care Services.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>07/10/2020</b></td> <td style="text-align: center;"><b>08/07/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/10/2020</b>	<b>08/07/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/10/2020</b>	<b>08/07/2020</b>				

**Kayla Portraz**

Provider Signature

**06/10/2020**

Date

**Stacy Wildermuth**

Inspector Signature

**06/10/2020**

Date