

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Growing Dreams Learning Center**

City: **Freeman**

Provider Number: **010605489**

Inspector: **Kenneth Anderson**

Date of Inspection: **07/18/2018**

Time of Inspection: **8:51 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>The storage cabinets in rooms six and seven have combustible materials stored less than 2 feet from the ceiling.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/20/2018</td> <td style="text-align: center;">07/19/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	07/20/2018	07/19/2018
Suggested Completion Date:	Actual Completion Date:				
07/20/2018	07/19/2018				

Sheila Epp

Provider Signature

07/18/2018

Date

Kenneth Anderson

Inspector Signature

07/18/2018

Date