

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - Non-School Location Compliance Plan

Provider's Name: **Volunteers of America Youth Center**

City: **Sioux Falls**

Provider Number: **010606010**

Inspector: **Eric Janke**

Date of Inspection: **12/05/2018**

Time of Inspection: **3:30 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

1. Are written emergency evacuation plans posted? 67:42:14:28

<p>Corrections To Be Made:</p> <p><b>There are no evacuation plans posted.</b></p> <p><b>***The evacuation plans are posted in each classroom.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>12/31/2018</b></td> <td style="text-align: center;"><b>01/08/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>12/31/2018</b>	<b>01/08/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>12/31/2018</b>	<b>01/08/2019</b>				

14. Is electrical system being used properly? 61:15:01 NOTE: Check for overloads or frayed extension cords.

<p>Corrections To Be Made:</p> <p><b>The computer lab has power strips daisy chained to each other. The power strips need to be plugged directly into the wall outlet.</b></p> <p><b>***The power strips are no longer connected to each other and are being used as required.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>12/13/2018</b></td> <td style="text-align: center;"><b>01/08/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>12/13/2018</b>	<b>01/08/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>12/13/2018</b>	<b>01/08/2019</b>				

## B. ENVIRONMENTAL HEALTH

25. Are children's hands washed before and after meals, and after using the restroom? 67:42:11:33

Corrections To Be Made:	Agency Action:	
<b>Children use a hand sanitizer before eating. The children must wash their hands with soap and water before and after meals. Hand sanitizer cannot be substituted for handwashing.</b>	<b>Compliance Plan</b>	
<b>***The children are washing their hands before and after snacks using soap and water.</b>	Suggested Completion Date:	Actual Completion Date:
	<b>12/06/2018</b>	<b>12/10/2018</b>
	Status: <b>Corrected</b>	

39. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:	Agency Action:	
<b>There is no documentation available for the annual heating and cooling inspection.</b>	<b>Compliance Plan</b>	
<b>***Verification of the current heating and cooling system was received by Child Care Services.</b>	Suggested Completion Date:	Actual Completion Date:
	<b>12/31/2018</b>	<b>12/10/2018</b>
	Status: <b>Corrected</b>	

**Rob**  
 \_\_\_\_\_  
 Provider Signature

**12/05/2018**  
 \_\_\_\_\_  
 Date

**Eric Janke**  
 \_\_\_\_\_  
 Inspector Signature

**12/05/2018**  
 \_\_\_\_\_  
 Date