

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **B&G Club Brandon Elementary ASE**

City: **Brandon**

Provider Number: **010606119**

Inspector: **Elijah Ehresmann**

Date of Inspection: **10/02/2019**

Time of Inspection: **3:47 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

17. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p><b>A current heating/cooling inspection was not available at time of inspection.</b> *Documentation received on 11/04/19.</p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>11/02/2019</b></td> <td style="text-align: center;"><b>11/04/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>11/02/2019</b>	<b>11/04/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>11/02/2019</b>	<b>11/04/2019</b>				

**Amber Kruger**

Provider Signature

**10/02/2019**

Date

**Elijah Ehresmann**

Inspector Signature

**10/02/2019**

Date