

Family Day Care New Location Monitoring Checklist Compliance Plan

Provider's Name: **Katherine Blachford**

City: **Box Elder**

Provider Number: **010609279**

Inspector: **Tina Uecker**

Date of Inspection: **02/26/2020**

Time of Inspection: **12:59 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health and Safety Features of the Home - Indoor Environment

26. Is there a fully charged, portable fire extinguisher, with a minimum 2A rating, kept near the food prep area? 67:42:03:11.02

<p>Corrections To Be Made:</p> <p>Provider did not have a 2A rated fire extinguisher. A 2A rated fire extinguisher must be kept near the food prep area</p> <p>*Provider recently moved and now has her 2A rated fire extinguisher.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/15/2020</td> <td style="text-align: center;">03/25/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/15/2020	03/25/2020
Suggested Completion Date:	Actual Completion Date:				
03/15/2020	03/25/2020				

34. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower? 67:42:03:11.05

<p>Corrections To Be Made:</p> <p>Hot water temperature was 121.2 degrees. Water temperature must be less than 120 degrees.</p> <p>*Hot water temperature was lowered.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/15/2020</td> <td style="text-align: center;">03/25/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/15/2020	03/25/2020
Suggested Completion Date:	Actual Completion Date:				
03/15/2020	03/25/2020				

Katherine Blachford

Provider Signature

02/26/2020

Date

Tina Uecker

Inspector Signature

02/26/2020

Date