

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Kreative Kidz LLC**

City: **Mobridge**

Provider Number: **011102517**

Inspector: **Clint Rux**

Date of Inspection: **02/12/2020**

Time of Inspection: **11:25 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p>Fire extinguishers did not have a current inspection tag.</p> <p>CORRECTION: Provider submitted verification of current inspection tag.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/12/2020</td> <td style="text-align: center;">02/19/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/12/2020	02/19/2020
Suggested Completion Date:	Actual Completion Date:				
03/12/2020	02/19/2020				

Kristi Rahlf

Provider Signature

02/12/2020

Date

Clint Rux

Inspector Signature

02/12/2020

Date