

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Bright Beginnings Child Care Center**

City: **Summerset**

Provider Number: **016598190**

Inspector: **Jon Farrar**

Date of Inspection: **03/15/2018**

Time of Inspection: **3:13 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Miscellaneous Rule Violations

61:15:01 - Fire Safety Standards

<p>Corrections To Be Made:</p> <p>Install single action hardware on both front doors. Remove deadbolt from middle exit door (off main front entry).</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/19/2018</td> <td style="text-align: center;">03/22/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/19/2018	03/22/2018
Suggested Completion Date:	Actual Completion Date:				
03/19/2018	03/22/2018				

Rachel Hepper

Provider Signature

03/15/2018

Date

Jon Farrar

Inspector Signature

03/15/2018

Date