

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Challenging Minds**

City: **Summerset**

Provider Number: **016598599**

Inspector: **Jon Farrar**

Date of Inspection: **02/25/2019**

Time of Inspection: **9:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>Exit sign at the rear entrance to medical clinic used for child care is not illuminated. Repair or replace to ensure it is illuminated. Correction: Program repaired the lighting in the exit sign.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/07/2019</td> <td style="text-align: center;">03/07/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/07/2019	03/07/2019
Suggested Completion Date:	Actual Completion Date:				
03/07/2019	03/07/2019				

Stacey Phillips

Provider Signature

02/28/2019

Date

Jon Farrar

Inspector Signature

02/28/2019

Date