

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Little Learners Preschool & Daycare**

City: **Emery**

Provider Number: **018040579**

Inspector: **Ron Werner**

Date of Inspection: **05/22/2018**

Time of Inspection: **10:34 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

<p>Corrections To Be Made:</p> <p>Stroller in emergency exit corridor</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">05/22/2018</td> <td style="text-align: center;">05/22/2018</td> </tr> <tr> <td colspan="2">Status: Corrected</td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	05/22/2018	05/22/2018	Status: Corrected	
Suggested Completion Date:	Actual Completion Date:						
05/22/2018	05/22/2018						
Status: Corrected							

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

Corrections To Be Made:	Agency Action:	
Bathroom hot water was 127 degrees	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	06/05/2018	06/02/2018
	Status: Corrected	

C. FOOD SERVICE

79. Are food containers properly stored, such as a minimum of six inches above the floor in a manner that protects from contamination and permits easy cleaning of the area, not stored under exposed or unprotected sewer or water lines, except for automatic fire system sprinkler heads, and are not in toilet rooms or vestibules? 67:42:11:18

Corrections To Be Made:	Agency Action:	
Cases of food stored on floor in storage room	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	05/23/2018	05/22/2018
	Status: Corrected	

kristen storms
Provider Signature

05/22/2018
Date

Ron Werner
Inspector Signature

05/22/2018
Date