

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SF Housing Family Self-Sufficiency**

City: **Sioux Falls**

Provider Number: **018041860**

Inspector: **Kelly Gnat**

Date of Inspection: **10/23/2018**

Time of Inspection: **2:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

37. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

<p>Corrections To Be Made:</p> <p>Water temp needs to be adjusted to 120 or below. Currently it is at 122. *Water tested again on 10/26/18. Currently measured at 120 degrees and faucets are equipped with scald guards.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/31/2018</td> <td style="text-align: center;">10/26/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/31/2018	10/26/2018
Suggested Completion Date:	Actual Completion Date:				
10/31/2018	10/26/2018				

Teresa Lucus

10/23/2018

Provider Signature

Date

Kelly Gnat

10/23/2018

Inspector Signature

Date