

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SF Housing Family Self Sufficiency Program**

City: **Sioux Falls**

Provider Number: **018041860**

Inspector: **Elijah Ehresmann**

Date of Inspection: **10/10/2019**

Time of Inspection: **11:54 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

37. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?

67:42:11:09

<p>Corrections To Be Made:</p> <p><b>Scald guards are placed on the handsinks that the children use. Temperature of is still 128 degrees. Water to be no more than 120 degrees. *Mixing valves installed as of 10/21/19. Water temperature measured at 115 degrees on 10/22/19.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>11/10/2019</b></td> <td style="text-align: center;"><b>10/22/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>11/10/2019</b>	<b>10/22/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>11/10/2019</b>	<b>10/22/2019</b>				

Lisa Bartell

Provider Signature

10/10/2019

Date

Elijah Ehresmann

Inspector Signature

10/10/2019

Date