

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SF Housing Family Self Sufficiency Program Child Care Center**

City: **Sioux Falls**

Provider Number: **018041860**

Inspector: **Elijah Ehresmann**

Date of Inspection: **01/16/2020**

Time of Inspection: **3:17 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

6. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p>There is a power strip behind the computer in the main care room that is not shielded or childproof. *Child Proof device observed on 01/30/2020</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">01/26/2020</td> <td style="text-align: center;">01/30/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	01/26/2020	01/30/2020
Suggested Completion Date:	Actual Completion Date:				
01/26/2020	01/30/2020				

7. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>The emergency lights of both exit signs in the main care room are not functioning when tested. *Emergency lights observed to be functional on 01/30/2020</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">02/16/2020</td> <td style="text-align: center;">01/30/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	02/16/2020	01/30/2020
Suggested Completion Date:	Actual Completion Date:				
02/16/2020	01/30/2020				

Lisa Bartell

Provider Signature

01/16/2020

Date

Elijah Ehresmann

Inspector Signature

01/16/2020

Date