

Family Day Care Inspection Compliance Plan

Provider's Name: **Kristina Pieschke**

City: **Sioux Falls**

Provider Number: **018041898**

Inspector: **Denise Ferguson**

Date of Inspection: **08/15/2018**

Time of Inspection: **8:19 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health & Safety Features of the Home - Indoor Environmental Observations

69. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower?
67:42:03:11.05

Corrections To Be Made:

144 degrees, must be 120 degrees or below. Water temperature was adjusted lower during the visit.

8/16/18 - Water temperature measured at 115 degrees.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/15/2018

Actual
Completion
Date:

08/16/2018

Status: **Corrected**

Kristina Pieschke

Provider Signature

08/15/2018

Date

Denise Ferguson

Inspector Signature

08/15/2018

Date