

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Central Baptist Preschool**

City: **Sioux Falls**

Provider Number: **018042174**

Inspector: **Kelly Gnat**

Date of Inspection: **10/03/2019**

Time of Inspection: **11:07 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p><b>The exit sign near the back door in the Blue Room is not illuminated. The lightbulb or battery needs to be replaced.</b></p> <p><b>***The lightbulb has been replaced in the exit sign and it is now operational.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>10/31/2019</b></td> <td style="text-align: center;"><b>10/22/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>10/31/2019</b>	<b>10/22/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>10/31/2019</b>	<b>10/22/2019</b>				

**Melissa Luden**

**10/03/2019**

Provider Signature

Date

**Kelly Gnat**

**10/03/2019**

Inspector Signature

Date