

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Central Baptist Preschool**

City: **Sioux Falls**

Provider Number: **018042174**

Inspector: **Carrie Lewis**

Date of Inspection: **09/30/2020**

Time of Inspection: **1:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p><b>The electrical outlets in the classrooms do not contain self-closing or tamper-resistant electrical covers.</b></p> <p><b>***All outlets that are accessible to children in the program have been replaced with self-closing outlets.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>10/01/2020</b></td> <td style="text-align: center;"><b>10/14/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>10/01/2020</b>	<b>10/14/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>10/01/2020</b>	<b>10/14/2020</b>				

**Melissa Ludens**

**09/30/2020**

**Carrie Lewis**

**09/30/2020**

Provider Signature

Date

Inspector Signature

Date