

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Early Explorers Learning Center**

City: **Tea**

Provider Number: **018043000**

Inspector: **Kelly Gnat**

Date of Inspection: **05/04/2020**

Time of Inspection: **12:15 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

1. Are written emergency evacuation plans posted? 67:42:10:18

<p>Corrections To Be Made:</p> <p><b>Emergency evacuation plans to be posted. *Plans observed on 05/28/2020</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>06/04/2020</b></td> <td style="text-align: center;"><b>05/28/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>06/04/2020</b>	<b>05/28/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>06/04/2020</b>	<b>05/28/2020</b>				

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p><b>Electrical outlets to be self-closing or tamper resistant. *All outlets installed are tamper resistant. Observed on 05/28/2020.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>06/04/2020</b></td> <td style="text-align: center;"><b>05/28/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>06/04/2020</b>	<b>05/28/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>06/04/2020</b>	<b>05/28/2020</b>				

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:  <b>Exit signs to be installed and operational</b> <b>*Exit signs observed and tested on 05/28/2020</b>	Agency Action:  <b>Compliance Plan</b>  Suggested Completion Date: <b>06/04/2020</b>  Status: <b>Corrected</b>	Actual Completion Date:  <b>05/28/2020</b>
--	---	--

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:  <b>Fire extinguishers to be installed</b> <b>*Extinguishers observed in the building on 05/28/2020</b>	Agency Action:  <b>Compliance Plan</b>  Suggested Completion Date: <b>06/04/2020</b>  Status: <b>Corrected</b>	Actual Completion Date:  <b>05/28/2020</b>
--	---	--

Lacey Cooper  
Provider Signature

05/04/2020  
Date

Kelly Gnat  
Inspector Signature

05/04/2020  
Date