

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Truks-N-Trykes Early Learning Care** City: **Sioux Falls**

Provider Number: **018043015**

Inspector: **Elijah Ehresmann** Date of Inspection: **08/07/2020**

Time of Inspection: **12:02 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

22. Does the construction of walls, ceilings, doors, window and skylights appear clean and in good repair? Does outside appearance and construction appear in good repair? 67:42:11:39

<p>Corrections To Be Made:</p> <p>There are multiple damaged areas on the walls in the classroom bathrooms where there were posters hanging. The walls need to be in good repair.</p> <p>**The holes in the walls have been patched and painted.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">09/07/2020</td> <td style="text-align: center;">08/17/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	09/07/2020	08/17/2020
Suggested Completion Date:	Actual Completion Date:				
09/07/2020	08/17/2020				

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower? 67:42:11:09

<p>Corrections To Be Made:</p> <p>The handwash sink temperatures range from 110F -127F. The water temperature needs to be 120F or below.</p> <p>***The water temperature has been adjusted and is below 120 degrees in all classrooms.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/14/2020</td> <td style="text-align: center;">09/08/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/14/2020	09/08/2020
Suggested Completion Date:	Actual Completion Date:				
08/14/2020	09/08/2020				

Heather Groos

Provider Signature

08/07/2020

Date

Elijah Ehresmann

Inspector Signature

08/07/2020

Date