

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Raider Academy**

City: **Gayville**

Provider Number: **019524008**

Inspector: **Stacy Wildermuth**

Date of Inspection: **08/22/2018**

Time of Inspection: **7:36 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

<p>Corrections To Be Made:</p> <p><b>Multiple emergency exits in the basement were found blocked during inspection. Window in the room used for storage downstairs was blocked by strollers and other items. The door to the outside was found locked and a table was in front of it so it could not be opened completely. Emergency exits must not be obstructed at all times.</b></p> <p><b>The program is currently not using the basement for child care. The emergency exits were unblocked and will remain unobstructed at all times.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td>Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td><b>08/23/2018</b></td> <td><b>09/12/2018</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>08/23/2018</b>	<b>09/12/2018</b>
Suggested Completion Date:	Actual Completion Date:				
<b>08/23/2018</b>	<b>09/12/2018</b>				

Kelly  
Provider Signature

08/23/2018  
Date

Stacy Wildermuth  
Inspector Signature

08/23/2018  
Date